


## MINIMUM 65.25 2 X 8 STUDS 11.75 MINIMUM MINIMUM 5/8" DRYWALL 1 HOUR FIRE RATING OPENING OPENING LINE ENTIRE CAVITY (5 SIDES) FIXTURE WHIP w/ CONNECTORS CONNECTION MADE AT JUNCTION BOX 5/8" DRYWALL 1 HOUR FIRE RATING SUBFLOOR JUNCTION BOX ON TOP OR SIDE MIN. 2 x 8 -ADJUSTABLE TABS 4.00 SURFACE VIEW -70.25

## **INSTALLATION TYPES**







## WARNINGS:

- This frame is ONLY to be used on a flat non-sloped ceiling.
- Heater must face straight down.
   Frame and Heater cannot be installed
- Frame and Heater cannot be installe on a pitched angle.

## NOTES:

- Heater suspends (Gravity) by resting on adjustable tabs in flush mount fixture.
- Mounting holes on Surface Flange to be determined and drilled by Contractor/Installer.
- Supplied with Hi-Temp Fixture Whip and Hi-Temp Ceramic Wire Nuts.
- **Note:** Please contact factory for longer length whips available for purchase.
- Coil excess flex into heater cavity.
- Use Licensed Electrician ONLY



15700 S. Figueroa St. Gardena, California 90248 Phone: (310) 354-1250 Fax: (310) 523-3674

ITEM #: X-18-2305 MATERIAL: 304 S.S. #4 FINISH

DESCRIPTION: W-61 FLUSH MOUNT PLASTER FRAME
(FOR USE WITH 61½" HEATERS)

NOTES:

SUPPLIED w/ ELECTRICAL FIXTURE WHIP

DATE: | SCALE: | DRAWN BY: | Aug.15, 2017 | N/A | MD